

#### Enhanced Nitrogen Removal Using Upflow Biological Filtration


November 30, 2005 B. Stitt, G. Welch

METCALF&EDDY AECOM

### **Presentation Outline**


- Background
- Need for Project CT General Permit
- Evaluation of Alternatives
- Project Delivery
- Implementation
- Summary

# Background



# Background

- Cheshire, CT WPCP
  - 3.5 MGD (Ave. day)
  - Employs Advanced Secondary Treatment (Nitrification)



- Determined that State water quality standards for Long Island Sound violated during summer months (< 6 mg/L DO)
- Nitrogen loading and subsequent algal growth/ death/ decay identified as primary cause of the hypoxia in Long Island Sound (low DO)
- CT DEP identified the need to reduce baseline TN loading from WPCP's by 65%

- General Permit for Nitrogen Dischargers Developed
- Permit established the maximum acceptable annual mass loading of TN from each municipal WPCP
- For Cheshire 78.3% reduction from 1997 to 1999 loadings

POTW	Equivalency Factor	Total Nitrogen (lbs/day)					
		2002	2003	2004	2005	2006	2014
Cheshire	0.49	205	190	173	151	125	103

Waste Load Allocation


- Flows and Loads are Increasing above 1997-1999
  - 475 lbs/day in 1997-1999
  - 730 lbs/day at design flow (2014)
  - 2014 WLA (103 lbs/day)
- TN Limit of 3.5 mg/l (at design flow)
- NH3 + Organic N component ~ 2.0 mg/l
- Effluent NOx-N Concentration of 1.5 mg/l

- WPCP's not meeting their TN limit must purchase credits to meet their waste load allocation
- WPCP's removing more TN than required can sell nitrogen credits
  - Credit Cost = <u>Total Annual Project Costs</u> Total Annual Reduction of Nitrogen

2004 Credit Cost = \$2.14 / Ib TN (expected to increase)

### **Alternatives Evaluation**

- Do nothing and pay annual credit cost (\$115 K in 2003)
- In tank modifications to remove some nitrogen (and pay annual credit cost for remainder)
- In tank modifications plus post DN using conventional anoxic tank
- In tank modification plus post DN using BAF
- BAF with no in tank modifications




## **Alternatives Evaluation**


- BAF Recommended Over Alternatives
  - No reduction in current plant capacity
  - Minimal impact on existing facilities during construction
  - Ability to meet 1.5 mg/l NOx-N limit
  - Most cost effective based on life-cycle cost analysis
    - Buying/ selling credits
    - Methanol use



# **Biological Processes - Nitrification**




At least two different species of autotrophic bacteria are responsible for the conversion of ammonia to nitrate



The denitrification process was believed to be the "easier" part of the equation - not quite true when low TN levels are required

# **Alternatives Evaluation**

- Attached Growth Biological Processes
- Upward Flow Through a Granular Media
  - Media Surface for denitrifying organisms
  - Media Solids removal



# **Project Delivery**

- Equipment Pre-Selection
- Design Based on Pre-Selected Vendors Equipment
- Conventional Bid with Line Item for DN Filter
- Contractor Purchased DN Filters
- Single Construction Contract with Owner

#### Project Delivery – Vendor Selection

- Pre-Selection via a Request for Proposal (RFP)
  - Meet 1.5 mg/I NOx-N Limit
  - RFP Defined Scope of Supply
    - Flow Control Equipment
    - Filter Media and Media Retention Systems
    - Instrumentation
    - Control Logic for Filter and MeOH Dose Control
    - Ancillary equipment for complete system
- RFP Required all Information Necessary for PW Cost Evaluation

### Project Delivery – Vendor Selection


- Two Manufactures Known at the Time of the Study
  - Kruger (Veolia Water)
  - Ondeo Degremont (now Infilco Degremont)
- Differences Between Manufactures
  - Media (polystyrene balls vs. granular biolite)
  - Media Retention Systems
  - Backwash Direction
  - Backwash Storage




## **DN Filter Differences**

Parameter	Kruger Biostyr	IDI Biofor
Filter Cells	5 cells 755 sf total filter area 9.18 ft media depth	4 cells 583 sf total filter area 10 ft media depth
Operation at AD Conditions	3 cells in operation 176 lbs/d/1,000 cf 5.4gpm/sf	3 cells in operation 167 lbs/d/1,000 cf 5.6 gpm/sf
Operation at Peak Hydraulic Conditions	4 cells in operation 9 gpm/sf	3 cells in operation 12.3 gpm/sf
Backwash Operation	Gravity 1 every 18 hours 15 minute downtime	Pumped 1 every 18 hours 38 minute downtime

# Kruger BioStyr




#### Infilco-Degroment BioFor



# Kruger BioStyr



Biostyr Media Retention Platform



Biofor Media Retention Fence

# Kruger BioStyr



Nyborg, Denmark



Hobro, Denmark

# Infilco-Degroment BioFor



Frankfurt Main Plant, Germany


#### Project Delivery – Vendor Selection

- Capital cost for DN filter equipment, concrete tanks, building and all ancillary equipment
- O&M cost for power, media replacement, etc.
- Present worth costs for two systems almost identical
- Selection came down to
  - Bid exceptions
  - Owner preferences
  - Demonstrated performance (both systems provided data demonstrating past performance)

# Influent and Effluent Requirements

Parameter	Influent Conditions	Effluent Requirements
Annual Average flow	3.50 mgd	NA
Minimum Flow	0.50 mgd	NA
Peak Hourly Flow	7.75 mgd	NA
Temperature	13 Degrees C (minimum)	NA
Dissolved Oxygen	Less than 7.0 mg/l	NA
Total Nitrogen	27.5 mg/L (annual ave.)	NA
Total Kjeldahl Nitrogen	2.0 mg/L (annual ave.)	NA
Ammonia Nitrogen	0.5 mg/L (annual ave.)	NA
Nitrate/Nitrite (NO <sub>X</sub> – N)	25.1 mg/L (annual ave.) varying from 41.5 mg/l to 11.5 mg/l	1.5 mg/l (annual ave.)
BOD <sub>5</sub>	6.0 mg/L (annual ave.) varying from 24.0 mg/l to 1.0 mg/l	Influent BOD <sub>5</sub> + 5.0 mg/l
TSS	6.0 mg/L (annual ave.) varying from 19.0 mg/l to 1.0 mg/l	10 mg/l (monthly ave.) 20 mg/l (max. day)

#### Implementation








# Questions?

# Infilco-Degroment BioFor



#### Kruger BioStyr

