

Improving our environment by controlling existing thermal power and desalination plants emission

A study of emission control in an existing thermal power and
desalination plant

By

Engr.

Abdullah H. Hodhan

**Operation Division Manager
J2&J3**

Engr.

Mohammad N. Al Dahlawi

Desalination Specialist

TABLE OF CONTENTS

- INTRODUCTION
- OBJECTIVE
- DISCUSSION
- LIFE ASSESMENT STUDY
 - COSTS
 - PERFORMANCE RELAIABILITY
 - ECONOMICAL EVALUATION
- ENVIRONMENTAL IMPACT STUDY
 - ENVIRONMENTAL CONSIDARATION
 - FUEL OIL SPECIFICATION
 - POLLUTANTS TREATMENTS
- CASE STUDY
 - FESABLE FGD PROCESS
 - FINAL EVALUATION OF FEASIBLE PROCESSES
- CONCLUSION
- RECOMMENDATION


INTRODUCTION

Thermal power and desalination plants are major sources of pollution in the Kingdom of Saudi Arabia. The government has assigned PME for the control of pollution, protection of environment and to help in the planning, designing, executing and operating of these facilities; that will be applied in a manner which shall not adversely effect the population

PME (Presidency of Metrology and Environment)



Objective of the study



To reduce thermal power & desalination plants emission to meet PME standards which shall help in promoting health, safety, welfare of the population and protecting kingdom's environment in general.

Discussion of the study

In order to reach that objective two studies have to be carried out:

- 1) Life assessment study of the existing plant.***
- 2) Environmental impact study***

Life assessment study of an existing Plant



1

Costs

2

Performance and Reliability

3

Economical Evaluation

5/18/2007

6

Costs

The existing plant costs include the following:

1) Fixed Cost

Is the capital invested in the installation of that plant and includes the following :

- a) Land, Building and Equipment cost.
- b) Interest
- c) Depreciation
- d) Insurance
- e) Management cost

2) Operating cost

Includes the following :

- a) Maintenance cost
- b) Spare parts cost
- c) Fuel and chemical cost.

3) Total cost is the sum of fixed cost and operation cost.



Performance and Reliability

Majority of power and desalination plants in Saudi Arabia are financed by the government. However, it must be efficient and cost effective to exploit the national resources. The prime duty of a designer is to design a plant which produce its product at the lowest cost and highest overall efficiency and reliability.



Economical evaluation of an existing plant

1) In order to consider any plant as economically feasible the following items must be covered:

- a) Recovery of the fixed cost of the plant.
- b) Recovery of the operating cost.
- c) Satisfactory profit.

2) To evaluate an existing plant to predict the return period of its initial investment and the expected profit gained, two financial indicators are commonly used:

- a) Pay back method.
- b) Net present value method.



Environmental impact study



1

Environmental Consideration

2


Fuel oil Specification

3

Pollutant treatments

5/18/2007

10



POLLUTANTS

Burning fuel results in

Gaseous components

Solid Components

Suspended

Precipitated

CO_x

SO_x

NO_x

Carbon
ash

Nickel

Vanadium

Pollutants resulting from fuel combustion

Environmental considerations

The main environmental aspect in connection with the study are as follows:

	1. Stack emissions.	
	2. Sea water effluents.	
	3. Soot.	

Stack emissions

The most critical parameters to be maintained according to PME limits in stack emissions

Dust

SO₂

The following table shows the emission concentration of pollutants in the flue gas from Jeddah SWCC phase# 4 stack:

pollutants	unit	current	PME	future
Dust	mg\Nm³	370	142	<50
	mg\MJ	112	43	<15
SO₂ <i>*at 55% efficiency of absorber</i>	mg\Nm³	5400	3200	<2400
	mg\MJ	1700	1000	<750
SO₂ <i>*at 65% efficiency of absorber</i>	mg\Nm³	5400	3200	<1900
	mg\MJ	1700	1000	<600

Sea water effluent

The most critical parameters to be maintained according to permissible PME limits

pH


Chemical Oxygen Demand (COD)

Heavy Metals (H.M.) included in the total suspended solids (TSS)

Sea water effluent at SWCC Jeddah Plant's outfall

Parameters	Unit	Current	PME	Future
Ph	-	> 8	6	≥6
COD	mg\ l	2.7	150	3
TSS	mg\ l	nil	15	Traces

SOOT




Fuel oil Specification

Parameter	Unit	Result	Test Method
Water Content	By crackle test	+ ve	ASTM D-95
Total acid number	Mg KOH/ gm	---	ASTM D-974
Kinematic Viscosity	Cst @50°C	169	ASTM D-445
Specific Gravity @ 15.6°C	-	0.963	ASTM D-1298
API Gravity	Degrees	15.44	ASTM D-287
Flash point (P.M. closed cup)	°C	77	ASTM D-93
Gross calorific value	J / g	43059	ASTM D-2382
Sulphur content	% W/W	3.41	ASTM D-129
Ash	% W/W	0.058	ASTM D-482
Sediments (by toluene extraction)	% W/W	0.024	ASTM D-473
Carbon residue (conradson)	% W/W	10.8	ASTM D-189
Vanadium	ppm	46	ASTM D-1548
Sodium	ppm	9.5	ASTM D-1318


Solid pollutant

The solid pollutant will be captured in the ESP as shown in figure



Gaseous pollutant treatment

The gaseous pollutant will be treated by F.G.D in the following way:



Case Study

This study has been carried out at SWCC Jeddah
plant phase# 4



1

Feasible FGD Processes

2

Final Evaluation of Feasible Processes

5/18/2007

21

Jeddah plant – phase 4

Commissioning Date :	Started 1981
Electrical generation:	5 Turbines, each produce 125 MW
Water production:	10 Desal Units, each produce 912 m³/h
Steam generation:	5 Boilers, each produce 600 tons / h
Flue gas emitted:	5 Boilers, each produce 500,000 nm³/h


Selection of Appropriate FGD Process

Consider the following factors:

- 1- Properties of fuel- amount of sulphur, ash & other constituents
- 2- Size of boiler- to determine the capacity of FGD equipment
- 3- Type of firing- To determine pollutants emitted
- 4- Availability of seawater
- 5- Cost of absorbent
- 6- Pollution control regulations (PME limits)

Feasible FGD Processes

1. Wet Processes
2. Dry Processes
3. Semi dry process
4. Other Processes



Only 3 FGD processes have been found to be feasible & economical for Jeddah Phase 4 use:

- **Alt 1. Sea water process**
- **Alt 2. Wet limestone/gypsum process**
- **Alt 3. Dry lime process**





Final evaluation of feasible processes

Two techniques have been used:

- 1) Economic evaluation**
- 2) Sensitivity evaluation**

Economic evaluation

no	Item	Unit	Alt1	Alt 2	Alt 3
1	Capital Investment	Million SR	273.75	281.25	236.25
2	Life Expectancy	Year	15	15	15
3	Operation & Maintenance cost	Million SR/ yr	42.2	53.0	57.75

Note: From the above table Alt 1 shows the lowest cost

Sensitivity Evaluation

Parameter Variation	Unit	Alt 1	Alt 2	Alt 3
Base case	Million SR/ yr	42.2	53.0	57.75
Investment -10% for Alt2 and Alt3	Million SR/ yr	42.2	49.2	54.5
- 5 Years life expectancy	Million SR/ yr	51.0	62.1	65.4
+ 5 Years life expectancy	Million SR/ yr	38.1	48.8	54.2
Discount rate + 2%	Million SR/ yr	46.2	57.2	61.2
Discount rate - 2%	Million SR/ yr	38.4	49.2	54.5

Note: From the above table Alt 1 shows the lowest cost

**The sea water FGD process is
considered to be the most appropriate**

CONCLUSION

To continue the running of an existing thermal power & desalination plant and satisfy PME requirements, two types of studies shall be carried out:

1) **Life assessment study.**

2) **Environmental impact study.**

A result of that it is possible to calculate the yearly total cost for the life extension, new FGD plant installations including capital investment, operation and maintenance costs.

RECOMMENDATION

To improve our environment and to comply with PME standards.

A) For future power and desalination plants, it is strongly recommended to install FGD system.

B) For existing plants, life expectancy and environmental impact assessment has to be carried out prior to take any decision by plants management.

